



DETAIL LEGEND:

- ① FX LUMINAIRE "C-IN" IN-GRADE FIXTURE PER PLAN.
- ② CONSTRUCTION SLEEVE
- ③ DRAINAGE MATERIAL PER PLAN
- ④ ADJACENT GROUND OR PAVEMENT SURFACE PER PLAN
- ⑤ DIRECT BURY, UF/UL, COPPER, LOW VOLTAGE CABLE WITH UL 486D (IEC/EN 60998) RATED WATERPROOF CONNECTION. LEAVE MINIMUM WIRE LOOP COILED BELOW FIXTURE FOR FUTURE SERVICE.

NOTES

- A. FIXTURE REQUIRES 11-15V AC/DC
- B. INSTALL TO A UL 1838 (IEC/EN 61347) LISTED TRANSFORMER
- C. DIG HOLE AND INSERT CONSTRUCTION SLEEVE. USE DRAINAGE MATERIAL BELOW SLEEVE. FILL SOIL OR CONCRETE TO TOP OF SLEEVE COVER (IF APPLICABLE). RUN WIRING INTO CONSTRUCTION SLEEVE.



C-IN, IN-GRADE

FXLuminaire. U.C-IN.01

NOT TO SCALE

REV: 2020-04-10