



8165 E Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Report No: L022212217



Report No: L022211217

Issue Date: 2/25/2022

Report Prepared For: FX Luminaire / Lumascape
1940 Diamond Street, San Marcos, CA, 92078

Model Number: FC-6LED-RG-FW-fl / nCOL10-6LED-FL-RG-WT

Test: Photometric/Colorimetric/Electrical Test

Standards Used: Appropriate part or all test guidelines were used for test performed:

IESNA LM79: 2019 Approved Methods for Electrical and Photometric Measurements of Solid-State Lighting Products

ANSI NEMA ANSLG C78.377: 2017 Specification of the Chromaticity of Solid State Lighting Products

ANSI C82.77-10:2014: Harmonic Emission Limits-Related Quality Requirements for Lighting Equipment

Description of Sample: Client submitted the sample. Received in working and undamaged condition. No modifications were necessary.

Special Test Condition: Fixture is tested with no special conditions.

Date of Tests: 2/23/22

Seasoning of Sample: No seasoning was performed in accordance with IESNA LM-79.

Equipment List

Equipment Used	Model No	Stock No	Calibration Due Date
Chroma Programmable AC Source	61604	PS-AC02	--
Yokogawa Digital Power Meter	WT210	MT-EL06-S4	4/7/23
HP Power Supply	6032A	PS-DC05-S2	--
Fluke Digital Thermometer	52K/J	MT-TP05	3/17/23
LLI Type C Goniophotometer System	RMG-C-MKII	CD-LL04-GC	--
LLI 2M Sphere	2MR97	CD-SN03-S2	--
LLI Spectroradiometer	SPR-3000	MT-SC01-S2	Before Use

General Information

Manufacturer:	FX Luminaire / Lumascape
Model Number:	FC-6LED-RG-FW-fl / nCOL10-6LED-FL-RG-WT
Driver Model Number:	N/A

Test Summary

Total Lumens:	514.00
Efficacy:	66.41
Color Redering Index:	83.7
Correlated Color Temperature:	2584
Input Voltage (VAC/60Hz):	12.00
Input Current (Amp):	0.7749
Input Power (W):	7.74
Input Power Factor:	0.8323
Current ATHD (%):	51.6%

Test Condition

Ambient Temperature (°C):	25.0
Stabilization Time (Hours):	0:45
Total Operating Time (Hours):	1:10





FIG. 1 LUMINAIRE

Colorimetry Test Results




CRI & CCT

x	0.4726
y	0.4176
u'	0.2675
v'	0.5319
CRI	83.70
CCT	2584
Duv	0.00162

R Values

R1	81.90
R2	91.37
R3	96.89
R4	83.78
R5	83.22
R6	92.58
R7	82.24
R8	57.83
R9	9.44
R10	81.89
R11	85.23
R12	82.14
R13	83.95
R14	98.94
R15	72.87





8165 E Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Report No: L022212217



Test Methods

Photometric Measurements - Goniophotometer

A Custom Light Laboratory Type C Rotating Mirror Goniophotometer was used to measure candelas(intensity) at each angle of distribution as defined by IESNA for the appropriate fixture type.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Spectral Measurements - Integrating Sphere

A Sensing Spectroradiometer SPR-3000, in conjunction with Light Laboratory 2 meter integrating sphere was used to measure chromaticity coordinates, correlated color temperature(CCT) and the color rendering index(CRI) for each sample.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Disclaimers:

The results related only to the samples as received and tested. This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government.

Report Prepared by : Kunjan Modi

Test Report Reviewed by:

Steve Kang
Quality Assurance

**Attached are photometric data reports.*



8165 E. Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Photometric Test Report

IES FLOOD REPORT

PHOTOMETRIC FILENAME : L022211217.IES

DESCRIPTIVE INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] L022211217
[TESTLAB] LIGHT LABORATORY, INC. (www.lightlaboratory.com)
[ISSUEDATE] 2/23/2022
[MANUFAC] FX Luminaire / Lumascape
[LUMCAT] FC-6LED-RG-FW-fl / nCOL10-6LED-FL-RG-WT
[LUMINAIRE] Lumiled, 6LED, 2700K, Flood (35°), Ring
[BALLASTCAT] N/A
[OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
[MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
[INPUT] 12VAC
[TEST PROCEDURE] IESNA:LM-79-08

Note: Candela values converted from Type-C to Type-B

CHARACTERISTICS


NEMA Type	4 H x 4 V
Maximum Candela	1064
Maximum Candela Angle	0H -1V
Horizontal Beam Angle (50%)	33.6
Vertical Beam Angle (50%)	33.0
Horizontal Field Angle (10%)	69.8
Vertical Field Angle (10%)	69.1
Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Beam Lumens	198
Beam Efficiency	N.A.
Field Lumens	407
Field Efficiency	N.A.
Spill Lumens	107
Luminaire Lumens	514
Total Efficiency	N.A.
Total Luminaire Watts	7.74
Ballast Factor	1.00

IES FLOOD REPORT
PHOTOMETRIC FILENAME : L022211217.IES

AXIAL CANDELA

DEG.	HOR.	DEG.	VERT.
90	0	90	0
85	2	85	2
75	3	75	3
65	8	65	7
55	19	55	17
47.5	37	47.5	32
42.5	63	42.5	51
37.5	87	37.5	88
33	120	33	109
29	176	29	156
25.5	255	25.5	224
22.5	333	22.5	291
19.5	428	19.5	379
17	521	17	468
15	600	15	546
13	678	13	622
11	772	11	719
9	856	9	807
7	929	7	887
5	984	5	950
3	1029	3	1007
1	1053	1	1043
0	1057	0	1057
-1	1053	-1	1064
-3	1029	-3	1051
-5	984	-5	1013
-7	929	-7	963
-9	856	-9	894
-11	772	-11	812
-13	678	-13	719
-15	600	-15	640
-17	521	-17	558
-19.5	428	-19.5	460
-22.5	333	-22.5	355
-25.5	255	-25.5	272
-29	176	-29	198
-33	120	-33	129
-37.5	87	-37.5	89
-42.5	63	-42.5	71
-47.5	37	-47.5	46
-55	19	-55	23
-65	8	-65	9
-75	3	-75	3
-85	2	-85	2
-90	0	-90	0

AXIAL CANDELA DISPLAY




Maximum Candela = 1064 Located At Horizontal Angle = 0, Vertical Angle = -1

H - Horizontal Axial Candela

V - Vertical Axial Candela

ISOCANDELA CURVES



Maximum Candela = 1064 Located At Horizontal Angle = 0, Vertical Angle = -1
50% Maximum Candela = 532
10% Maximum Candela = 106.4