



DETAIL LEGEND:

- ① FX LUMINAIRE "KT" FIXTURE PER PLAN.
- ② CONSTRUCTION SLEEVE
- ③ DRAINAGE MATERIAL PER PLAN
- ④ ADJACENT GROUND OR PAVEMENT SURFACE PER PLAN
- ⑤ DIRECT BURY, UF/UL, COPPER, LOW VOLTAGE CABLE WITH UL 486D (IEC/EN 60998) RATED WATERPROOF CONNECTION. LEAVE MINIMUM WIRE LOOP COILED BELOW FIXTURE FOR FUTURE SERVICE.

NOTES

- A. FIXTURE REQUIRES 11-15V AC/DC
- B. INSTALL TO A UL 1838 (IEC/EN 61347) LISTED TRANSFORMER
- C. DIG HOLE AND INSERT CONSTRUCTION SLEEVE. USE DRAINAGE MATERIAL BELOW SLEEVE. FILL SOIL OR CONCRETE TO TOP OF SLEEVE COVER (IF APPLICABLE). RUN WIRING INTO CONSTRUCTION SLEEVE.



IN-GRADE LIGHT (KT)

FXLuminaire. I.KT.01

NOT TO SCALE
REV: 2019-10-17